

Thermocable FE Ltd

Thermocable Cryogenic Detection Sensor

To whom it may concern,

The Thermocable type "Cryogenic" sensor cable has been independently compatibility tested for fire and fault monitoring by Hochiki Europe (UK) Limited.

Test results confirm suitability for use between the Thermocable Cryogenic sensor cable and the following Hochiki loop interface units.

Criteria:

Cable length 10m tested.

Thermocable RoCD Control Unit (Required).

EOL Module.

Products tested with the following Modules:-

CHQ-SIM (SCI), CHQ-SIM/DIN (SCI).

CHQ-POM (SCI), CHQ-POM/DIN (SCI).

CHQ-DRC (SCI), CHQ-DRC/DIN (SCI).

CHQ-MRC2, CHQ-MRC2/DIN (SCI).

CHQ-DZM, CHQ-DZM-/DIN (SCI). (Input & Zone)

If you have any enquiries please feel free to contact me directly.

Kind Regards

David Brown

Product Manager

HOCHIKI EUROPE (UK) LIMITED

Grosvenor Road, Gillingham Business Park,
Gillingham, Kent, ME8 0SA, United Kingdom

Telephone: +44 (0)1634 260133

Facsimile: +44 (0)1634 260132

e-mail (UK Sales): sales@hochikieurope.com

e-mail (Export): export@hochikieurope.com

www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,
Butlers Wharf, London SE1 2LR

Registered in England no. 2639909

VAT no. GB 573 8188 03