

CERTIFICATE OF COMPLIANCE

Certificate Number 20190122-S8976
Report Reference S8976-20050509
Issue Date 2019-JANUARY-22

Issued to: THERMOCABLE FLEXIBLE ELEMENTS LTD
PASTURE LN
CLAYTON
BRADFORD
BD14 6LU UNITED KINGDOM

**This certificate confirms that
representative samples of**

HEAT-ACTUATED DEVICES FOR SPECIAL
APPLICATION; HEAT-AUTOMATIC FIRE DETECTORS
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 521, Heat Detectors For Fire Protective Signaling
Systems
ULC S530-M91, Heat Actuated Fire Detectors For Alarm
Systems

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190122-S8976
Report Reference S8976-20050509
Issue Date 2019-JANUARY-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fixed temperature line type heat detector cable for special applications, Models TH68(p/n F1065), TH78(p/n F1066), TH88(p/n F1067), TH105(p/n F1068), TH185(p/n F1069), and VHT(p/n F1132); Models TH65+(p/n F1124), TH75+(p/n F1125), TH85+(p/n F1126), TH110+(p/n F1127), TH65SS+(p/n F1128), TH75SS+(p/n F1129), TH85SS+(p/n F1130), TH100SS+(p/n F1131)

Fixed temperature line type heat-automatic fire detectors, Models TH68(p/n F1065), TH78(p/n F1066), TH88(p/n F1067), TH105(p/n F1068), TH185(p/n F1069), and VHT(p/n F1132); Models TH65+(p/n F1124), TH75+(p/n F1125), TH85+(p/n F1126), TH110+(p/n F1127), TH65SS+(p/n F1128), TH75SS+(p/n F1129), TH85SS+(p/n F1130), TH100SS+(p/n F1131) +

NOTE: p/n = Part number



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

